

## Hakowski, Denise

---

**From:** Hakowski, Denise  
**Sent:** Friday, July 11, 2014 3:26 PM  
**To:** Kevin Coyne  
**Cc:** Walker, Dana  
**Subject:** Question about the Charleston WER

Hi Kevin,

Looked over everything today and I have a question.

I do not see in the report if the WER developed was total recoverable or dissolved. It does say in the report "total copper", should I take that to be total recoverable?

Just a reminder that total recoverable WERs should be applied to total recoverable criteria. As WV copper criteria is dissolved, that will need to be considered in developing the permit limit.

I'll be noting in our comment letter that whether the WER is total recoverable or dissolved should be noted in 7.2.d.1.9.2.

One more thing, you note in the summary that WVDEP evaluated the plant performance using sampling data, but you make not conclusion that the plant was operating normally. I'm assuming it was, but would be good to note if you all do future WERs.

Thanks, I'll put the supportive comments letter together next week.

Denise